

SUBPART 5-1

PUBLIC WATER SYSTEMS

(Statutory authority: Public Health Law, Section 225)

Sec.

GENERAL PROVISIONS

5-1.1 [Definitions](#)

SOURCES OF WATER SUPPLY

5-1.10 [Statement](#)

5-1.11 [Applicability](#)

5-1.12 [Water quality for existing sources of water supply](#)

5-1.13 [Sampling and analytical requirements](#)

5-1.14 [Water quality for proposed sources of water supply](#)

5-1.15 [Limitation](#)

PLANNING, SITING, TREATMENT AND APPROVAL

5-1.20 [Applicability](#)

5-1.21 [Siting requirements](#)

5-1.22 [Approval of plans and completed works](#)

5-1.23 [Reporting emergencies](#)

5-1.24 [Approval of fluoridation of public water systems](#)

5-1.25 [Disinfection of facilities](#)

5-1.26 [Dewatering trenches](#)

5-1.27 [Adequacy of distribution system](#)

5-1.28 [Blowoff facilities](#)

5-1.29 [Pumping equipment](#)

5-1.30 [Providing treatment for public water systems](#)

5-1.31 [Cross-connection control](#)

5-1.32 [Protection of equalizing and distribution reservoirs](#)

5-1.33 [Water supply emergency plans](#)

CONTROL OF COPPER AND LEAD IN DRINKING WATER

5-1.40 [Applicability](#)

5-1.41 [Lead and copper action levels](#)

5-1.42 [Monitoring requirements for lead and copper in drinking water](#)

5-1.43 [Monitoring requirements for water quality parameters](#)

- 5-1.44 [Public education and supplemental monitoring requirements](#)
- 5-1.45 [Corrosion control studies](#)
- 5-1.46 [Corrosion control treatment](#)
- 5-1.47 [Source water monitoring and treatment](#)
- 5-1.48 [Lead service line replacement](#)
- 5-1.49 [Reporting and record keeping requirements](#)

PUBLIC WATER SYSTEMS; MAXIMUM CONTAMINANT LEVELS;
MONITORING REQUIREMENTS;
NOTIFICATION REQUIREMENTS

- 5-1.50 [Applicability and responsibility](#)
- 5-1.51 [Maximum contaminant levels](#), maximum residual disinfectant levels and treatment technique requirements
- 5-1.52 [Tables](#)

MONITORING AND CONTROL OF DISINFECTION
BYPRODUCT PRECURSORS

- 5-1.60 [Applicability](#)
- 5-1.61 [Monitoring requirement for disinfection byproduct precursors](#)
- 5-1.62 [Alternative compliance criteria for enhanced coagulation](#)
- 5-1.63 [Enhanced coagulation performance requirements](#)

OPERATION AND QUALITY CONTROL

- 5-1.70 [Applicability](#)
- 5-1.71 [Protection and supervision of public water systems](#)
- 5-1.72 [Operation of a public water system](#)
- 5-1.73 [Water treatment plant laboratory](#)
- 5-1.74 [Approved laboratories](#)
- 5-1.75 [Additional sampling requirements](#)
- 5-1.76 [Monitoring of consecutive public water systems](#)
- 5-1.77 [State notification](#)
- 5-1.78 [Public Notification](#)
- 5-1.79 [Multiple distribution systems](#)

VARIANCES AND EXEMPTIONS

- 5-1.90 [Variance from a maximum contaminant level](#)
- 5-1.91 [Variance from required use of any specified treatment technique](#)
- 5-1.92 [Exemption from a maximum contaminant level or any](#)

[treatment technique
requirement](#)

5-1.93 [Variance or exemption requests](#)

5-1.94 [Notice and opportunity for public hearing](#)

5-1.95 Reserved

5-1.96 [Enforceability of final schedule prescribed pursuant to granting
of
variance or exemption](#)

SEPARABILITY

5-1.100 [Separability](#)

APPENDICES

5-A. [Recommended Standards for Water Works, 2003 edition](#)

5-B. [Standards for Water Wells](#)

5-C. [Acceptable Methods for the Analysis of Contaminants in Water](#)

5-D Special Requirements for Wells Serving Public Water Systems

TABLES

MAXIMUM CONTAMINANT LEVEL DETERMINATION

1. Inorganic chemicals and physical characteristics
2. Nitrate
3. Organic chemicals
- 3A. Maximum residual disinfectant level determination
4. Entry point turbidity
- 4A. Surface water turbidity
5. Distribution system turbidity
6. Microbiological
7. Radiological

MINIMUM MONITORING REQUIREMENTS

- 8A-D. Inorganic chemicals and physical characteristics
- 9A-D. Organic chemicals
10. Turbidity
- 10A. Turbidity
11. Microbiological
12. Radiological

NOTIFICATION

13. Required notification

CT DETERMINATION

14A-G. CT Values

MISCELLANEOUS

15. Disinfection monitoring for systems using chlorine or chloramines
-grab sample frequency instead of continuous monitoring

15A. Disinfection residual minimum monitoring requirements

Volume: A

Statutory Authority: Public Health Law, Section 225